



Centrum stavebního inženýrství a.s.

Fire Technical Laboratory

AUTHORIZED
BODY No. 212

NOTIFIED
BODY No. 1390

CLASSIFICATION OF REACTION TO FIRE IN ACCORDANCE WITH ČSN EN 13501-1+A1:2010

Applicant: Kronospan CRO
Slavonska cesta 17
430 00 Bjelovar
Croatia

Prepared by: Centrum stavebního inženýrství a.s.
Pražská 16
102 00 Praha 10
Czech Republic

Product name: *Kronospan Fireboard*

**Classification
report No.:** PK-12-021

Issue number: 1/2

Date of issue: 29th February 2012

This classification report consists of 4 pages and may only be used or reproduced in its entirety.

Address:
PRAŽSKÁ 16, 102 00 PRAHA 10, Czech Republic, E mail: csias@csias.cz, <http://www.csias.cz>
Reg. No. 45274860, VAT No. CZ45274860. The Company is registered in the Commercial Register administered by the Municipal Court of Prague (section B, inset 1595).
Fire Technical Laboratory, E-mail: ptl@csias.cz
Phone: +420 281 017 111, Fax: +420 281 017 455

1. DETAILS OF CLASSIFIED PRODUCT

Nature and end use application:

Classification of the product *Kronospan Fireboard* is valid for the following end use application:

Wooden particle board for construction.

Description:

The product *Kronospan Fireboard* is fully described in the test reports in support of the classification listed in clause 2.

2. TEST REPORTS AND TEST RESULTS IN SUPPORT OF THIS CLASSIFICATION

Test reports:

Name of laboratory	Name of sponsor	Test report ref. no.	Test method
CSI a.s., Fire technical laboratory	VVÚD, Praha, s.p.	15841 - 1/3	ČSN EN ISO 11925-2
		15841 - 2/3	
		15841 - 3/3	ČSN EN 13823

Test results:

Test method	Parameter	Number of test	Results	
			Continuous parameter mean (m)	Compliance parameters
ČSN EN ISO 11925-2 exposition = 30 s	$F_s \leq 150 \text{ mm}^{(1)}$	6	(-)	yes
	$F_s \leq 150 \text{ mm}^{(2)}$	6	(-)	yes
	ignition of the filter paper	12	(-)	no
ČSN EN 13823	$FIGRA_{0,4 \text{ MJ}} \text{ (W/s)}$	3	104,8	(-)
	$LFS > \text{edge}$	3	(-)	no
	$THR_{600 \text{ s}} \text{ (MJ)}$	3	4,2	(-)
	$SMOGRA \text{ (m}^2/\text{s}^2)$	3	0,0	(-)
	$TSP_{600 \text{ s}} \text{ (m}^2)$	3	24,0	(-)
	flaming droplets / particles[s]	3	0	no

(-): not applicable
 (1): surface flame attack
 (2): edge flame attack

3. CLASSIFICATION AND DIRECT FIELD OF APPLICATION

Reference and direct field of application

This classification has been carried out in accordance with the clause 11.6, 11.9.2 and 11.10.1 of ČSN EN 13501-1+A1:2010.

Classification

The product *Kronospan Fireboard*, in relation to its reaction to fire behaviour is classified:

B

The additional classification in relation to smoke production is:

s1

The additional classification in relation to flaming droplets/particles is:

d0

The format of the reaction to fire classification for *Kronospan Fireboard* is:

Fire behaviour		Smoke production			Flaming droplets	
B	-	s	1	,	d	0

Reaction to fire classification: B-s1, d0

Field of application

This classification is also valid for the following product parameters:

- thickness \geq 12 mm

This classification is valid for the following end use conditions:

- without substrate or fixed directly on the substrates of reaction to fire class at least A2-s1, d0 or A1

4. LIMITATIONS

Restrictions

This classification report is valid until 1st March 2017, provided that the technical specifications of the product will not be changed.

Warning

This document does not represent type approval or certification of the product.

Prepared:



Jiří Socha



Reviewed:



Vít Slaboch
head of laboratory